



## September 10, 2015 Docket W-20467A-10-0483 Decision # 72377

W-02467A-09-0333 W-02467A-09-0334 W-02467A-10-0483

## ORIGINAL

Arizona Corporation Commission DOCKETED


SEP 1 4 2015

DOCKETED BY

AZ CORP COMMISS.

DOCKET CONTROL

RECEIVED



## ARIZONA DEPARTMENT OF **ENVIRONMENTAL QUALITY**



## APPROVAL OF CONSTRUCTION

**Project Description:** 

Well #6 – Installation of a 10hp (70gpm) new source well

(55-210719), 620 linear feet of 6-inch C900 PVC water main,

and related appurtenances.

Location:

Chino Valley, AZ

**Project Owner:** 

**Granite Mountain Water Company** 

Address:

P.O. Box 350, Chino Valley, AZ 86323

The Arizona Department of Environmental Quality (ADEQ) hereby issues an Approval of Construction for the above-described facility based on the following provisions of Arizona Administrative Code (A.A.C.) R18-5-507 et seq.

On May 13th, 2015 William Joseph Carnes, P.E. certified that the project was built according to the as-built plans and specifications and ADEQ's Certificate of Approval to Construct.

On January 22<sup>nd</sup>, 2014, ADEQ issued a Certificate of Approval to Construct for the referenced project.

This Approval of Construction authorizes the owner to begin operating the abovedescribed facilities as represented in the approved plan on file with the ADEQ. Be advised that A.A.C. R18-4-203 requires the owner of a public water system to maintain and operate all water production, treatment and distribution facilities in accordance with ADEQ Safe Drinking Water Rules.

**RDR** 

PWS No.: 13-150

LTF No.: 62407

Manager

C: ADEQ File No.: 20130185

Yavapai County Health Department

**AZ Corporation Commission** 

Engineer

(602) 771-2300